

AAMA TEST RATINGS CHART

The below chart contains the results of our most recent AAMA Air, Water, & Structural Test Reports. Northeast is partnered with independent agency ALI & Intertek Labs to provide accurate test reports and information for all our products. The below records are updated as products are re-tested and renewed. Downloadable Test Reports & Explanations of each category can be found on our “Ratings” Page on our website. It is the responsibility of the owner, architect, or builder to make sure the product selected is in compliance with applicable laws & building codes.

MODEL	CPD #	RATING	DP	Water Resistance	Air Infiltration	Uniform Structure Load	Uniform Deflection Load	Forced Entry
DH900	NEW-A-2	R-PG50	50 psf	7.5 psf	0.27 cfm/ft ²	75 psf	50 psf	Grade 10
DH990	NEW-A-3	R-PG50	50 psf	7.25 psf	0.05 cfm/ft ²	75 psf	50 psf	Grade 10
SH660	NEW-A-13	R-PG50	50 psf	7.52 psf	0.16 cfm/ft ²	75 psf	50 psf	Grade 10
SL610	NEW-A-14	R-PG35	35 psf	5.25 psf	0.12 cfm/ft ²	52.50 psf	35 psf	Grade 10
PW630	NEW-A-15	R-PG50	50 psf	10.65 psf	0.01 cfm/ft ²	50 psf	75 psf	Grade 10
CW390	NEW-A-16	LC-PG50	50 psf	12.11 psf	0.01 cfm/ft ²	40 psf	60 psf	Grade 10
SL710 (4011)	NEW-A-19	R-PG35	35 psf	5.25 psf	0.2 cfm/ft ²	52.5 psf	35 psf	Grade 10
PW330 (4015)	NEW-A-22	R-PG60-FW	60 psf	12 psf	0.03 cfm/ft ²	90 psf	60 psf	Grade 10
PD400	NEW-A-23	R-PG35	35 psf	5.25 psf	0.07 cfm/ft ²	52.63 psf	35 psf	Grade 10
CW300	NEW-A-24	R-PG40	40 psf	6.06 psf	0.01 cfm/ft ²	60 psf	40 psf	Grade 10